

## **DIVISION 8 - DOORS AND WINDOWS**

### **Section 08400 - Entrances and Storefronts**

#### **Introduction**

Evaluate if future reglazing can be accomplished easily from the exterior.

#### **Part 1 - General**

- Consultant shall establish the minimum level of quality. System shall be “engineered”.
- Generally, these systems shall not incorporate operable windows.
- System shall accommodate the hardware components specified in Section 08710 - Finish Hardware. Substitutions of manufacturers standard hardware is not permitted.

#### **Part 2 - Products**

- Finishes shall be noted. If anodized or powder coated give class #.
- Determine if window washing hooks are necessary.
- Require design to provide for a simple re-glazing system.
- Specify the framing system. System shall provide positive drainage to the exterior.
- Entrance doors shall be minimum “wide style” type. Equivalent to Kawneer 500 series or approved equal.

#### **Part 3 - Execution**

- There are no unique University requirements.

#### **End of Section 08400**