

DIVISION 15 - MECHANICAL

Section 15810 - Humidifiers

Introduction

Equipment associated with air conditioning equipment.

Part 1 - General

- Provide only when absolutely necessary or when a special Project requirement is present.
- Decarbonization Item: For new construction or extensive renovations requiring humidifiers, the humidification source shall be locally generated within the building.
- Discuss with UFS Project Manager, Energy Manager, Controls Supervisor, and Mechanical Engineer before specifying.

Part 2 – Products

- Where used, humidifiers shall include a downstream high-humidity switch and a minimum air velocity switch.

Part 3 – Products

- Not Used

End of Section 15810