

## **DIVISION 16 - ELECTRICAL**

### **Section 16175 - Elevator Power and Controls**

#### **Introduction**

There are unique University requirements.

#### **Part 1 - General**

- Consultants shall provide details on plans, clearly reflecting the requirements within. The consultant shall not specify pre-manufactured equipment for machine room shunt trip and control requirements. Specifically note on the plans that the pre-manufactured items are not acceptable.
- **POWER**
  - The consultant shall specify generous circuitry that accommodates circuit sizing requirements by vendors notorious for requiring over sizing. Provide notations that require the contractor to provide system upgrades when elevator equipment requires larger capacity system components in excess of that shown on the construction documents. The consultant shall explicitly state in the specifications that these upgrades shall be performed without additional cost to the University. The consultant is directed to intentionally size feeders for worse case conditions.
  - Provide a minimum elevator machine room size of 100 square feet, exclusive of the area above the hoist way (for traction elevators), and without any odd corners, narrow passages, or structural interferences.
  - Main electrical elevator feed shall employ a molded case shunt trip breaker and a suitably sized enclosure. Larger enclosures for electronic type breakers are to be avoided as they take up too much room in an already cramped service space. Requirements for electrical coordination to be accomplished upstream of the main elevator feed.
- Power for a minimum of (1) elevator shall be on the life safety engine generator, when available.
- All conduit fittings shall be compression type. Set screw type are not allowed even when elevator is non-DSS compliant.

#### **Part 2 - Products**

- **SHUNT TRIP AND RELATED CONTROLS**
  - The machine shunt trip breaker shall be installed in an open face enclosure similar to the "Square D LA400S" to allow for rapid visual confirmation of a tripped breaker. The breaker shall be electronic type with LSI features, including short time adjustment. It shall have one N.O. and one N.C. contact for battery lowering disconnection and other future use.
  - Provide 120 Volt control system with switch, Neon Pilot and Current Limiting (CL) fuse.

**End of Section 16175**