# **DIVISION 16 - ELECTRICAL**

#### Section 16195 - Electrical Identification

#### Introduction

To provide ready identification of power source for maintenance personnel.

#### Part 1 - General

The following items are to be identified as to source of power:

Receptacles Safety Switches Motor Starters Junction boxes

Snap Switches on inside of plate with indelible felt-tip marker

The following items are to be identified as to what they service.

Safety Switches Motor Starters Panelboards Switchboards Time Clocks

The following items are to be identified to match the identification indicated on the drawings:

Panelboards Switchboards Transformers

Other items which require identification will be identified in the section pertaining to them.

### Part 2 - Products

- For panelboards, safety switches, motor starters, switch boards use black on white plastic engraved identification signs attached using #6 self tapping screws.
- For receptacles use clear acrylic labels self-adhesive by "Brother P-Touch" Equip. or approved equal. Print color shall be black for normal systems and red for emergency.
- · For wires use vinyl impregnated cloth tags.
- For color coding cables use vinyl marking tape.
- For j-boxes write in large letters on cover using an indelible magic marker. Where exposed, identification is to be on inside face of cover.
- Panelboards shall have typewritten directories indicating actual room numbers and any other pertinent information for the circuit served. (I.E. COPIER ROOM 131, EF-3, NW CORNER OF ROOF, RECEPTACLES E & W WALLS RM 242). Verify room numbers with University, prior to typing the directories. Use proper room numbers. Note new room numbers on as-built drawings.

## Part 3 - Execution

- Require that the new typewritten panel directories be installed after each project or remodel, updated to reflect all changes. Existing panel schedules shall be left in panel for reference.
- J-boxes for fire alarm circuits shall be painted RED and labeled using an indelible black marker "Fire Alarm".
- Identify ground wires and neutral conductors at all j-boxes, pull boxes, or wherever wires are accessible.
  Spiral tape continuous where accessible. Ground wires and neutral conductors size #8 and below will have colored insulation.
- COLOR CODES for new work shall be as follows:
- All conductors shall have integral colored insulation.

# **POWER WIRING**

PHASE	120/208 VOLTS	277/480 VOLTS 4160/13800 VOLTS
А	BLACK	BROWN
В	RED	ORANGE
С	BLUE	YELLOW
NEUTRAL	WHITE	GRAY
GROUND	GREEN	GREEN

## **FIRE ALARM WIRING**

Refer to Section 16720 (pg. 16720-7)

**End of Section 16195**