

## **DIVISION 16 - ELECTRICAL**

### **Section 16425 – Motor Controllers and Contactors**

#### **Introduction**

##### **Part 1 - General**

- Refer to Appendix Section 16425 and incorporate into project.
- Provide a comprehensive specification.
- Include the following in performing the design and specification:
  - Centers shall be 3 phase 4 wire.
  - Center shall have main disconnecting devices.

##### **Part 2 - Products**

- Refer to Appendix Section 16425 and incorporate into project.
- Subject to submittal approval.

##### **Part 3 - Execution**

- Refer to Appendix Section 16425 and incorporate into project.

#### **End of Section 16425**